

**SECTION 811 -- SLOPE PROTECTION NETTING**

**811.01 -- Description**

This work shall consist of furnishing and installing a slope protection netting at the locations shown in the plans.

**811.02 -- Material Requirements**

1. The slope protection netting shall be as shown in the NDR Approved Products List.
2. The pins for the netting shall be 10 inch U-pins with a 2 inch throat. The pin shall be made of 11 gauge (0.120 inch) diameter wire or heavier.

**811.03 -- Construction Methods**

1. The Contractor shall place the slope protection netting after the hay slope protection mulch is soil anchored and/or cleat crimped.
2. The netting shall be pinned to the ground as shown in the plans.

**811.04 -- Method of Measurement**

The quantity of slope protection netting for which payment will be made will be the number of square yards of slope protection netting placed over the surface of the completed work.

**811.05 -- Basis of Payment**

- | 1. | <u>Pay Item</u>          | <u>Pay Unit</u>  |
|----|--------------------------|------------------|
|    | Slope Protection Netting | Square Yard (SY) |
2. Payment is full compensation for all work prescribed in this Section.